

CITY OF SPARTA
6 Liberty Square
P.O. Box 30
Sparta, Tennessee 38583
931.836.3248
931.836.3941 fax
www.spartatn.com



CITY OF SPARTA Burley, Love, Riverview, Wagoner & Hwy 111 Sewer Projects REQUEST FOR BIDS

The City of Sparta Tennessee will receive sealed bids for Sewer Upgrades for **Burley**, **Love**, **Riverview**, **Wagoner Streets and Hwy 111** until 2:00 p.m. on Tuesday, September 20th, 2022. At that time the bids will be publicly opened and read aloud. Late bids will not be considered.

Bids are to be delivered to Sparta City Hall at 6 Liberty Square, PO Box 30 Sparta, TN 38583. Bid must be clearly marked "Bid for Sewer Project" on the outside of a sealed envelope. All bids must be signed.

No bid may be withdrawn for thirty (30) days from the date of the bid opening. Purchase orders will be issued only after approved by the Sparta Board of Mayor and Aldermen.

The City of Sparta reserves the right to reject any or all bids, to waive any irregularities in a bid. The City of Sparta reserves the right to accept any part, or all of a bid, or to accept that bid, (or bids) which in the judgment of the Board of Mayor and Alderman of the City of Sparta is in the best interest of the City. The purchaser also reserves the right to require a bidder to submit evidence of qualifications as may be deemed necessary by the City Administrator.

For further information regarding submission of a bid and to obtain bid packages, contact the City Administrator at Sparta City Hall, 6 Liberty Square, PO Box 30, Sparta, Tennessee 38583, telephone (931) 836-3248.

The City of Sparta does not discriminate based on race, color or national origin pursuant to Title VI of the Civil Rights Act of 1964 (42 U.S.C. 2000d).

RFB: Sewer Upgrades Burley, Love, Riverview, Wagoner St & Hwy 111 September 20th 2022






CITY OF SPARTA Burley, Love, Riverview, Wagoner & Hwy 111 Sewer Projects REQUIREMENTS FOR BIDDERS

- 1. Replace approximately 3,195 ft of 8 inch by pipe bursting.
- 2. An additional 160 ft of 8 inch SDR26 PVC or greater and 3 manholes to be replaced with extra crushed stone under base
- 3. Pre-camera all lines to locate services.
- 4. Service lines should be 6 inch schedule SRD26 PVC or greater. All services are required to have a cleanout box with a CI lid with the word "SEWER" ON TOP. All boxes shall be traffic rated and provided by the contractor.
- 5. Manholes casting will be replaced and new 26" and manholes not replaced shall be cement coated with inverts grouted.
- 6. Contractor shall be responsible for all traffic control.
- 7. All line connections to existing clay or plastic must use Max-Adapters, no Ferncos.
- 8. All crushed stone shall be the responsibility of the Contractor.
- 9. A manhole boot is required whenever a manhole is to be cored.
- City of Sparta personnel will inspect all construction for quality control.
- 11. All debris shall be disposed of at 545 E. Bockman Way at the designated location behind the Public Works building.
- 12.If Bypass Pumping is required, the contractor shall be responsible.
- 13. All lines require pressure testing
- 14. All new manholes require vacuum testing.

For any further questions or to schedule a time to visit the worksites please contact Public Works Director Dillard Quick at 931-738-2281.

See attached drawings



City of Sparta is not responsible for misuse, misinterpretation, or inaccuracy of data.

Not a substitute for OneCall.


Sewer - Burley St



1 in = 70 ft







City of Sparta is not responsible for misuse, misinterpretation, or inaccuracy of data.

Not a substitute for OneCall.

Sewer - Love St



1 in = 75 ft







City of Sparta is not responsible for misuse, misinterpretation, or inaccuracy of data.

Not a substitute for OneCall.


Sewer - Riverview Dr



1 in = 75 ft

8/1/2022





City of Sparta is not responsible for misuse, misinterpretation, or inaccuracy of data.

Not a substitute for OneCall.

Sewer - Wagoner St



1 in = 175 ft





City of Sparta is not responsible for misuse, misinterpretation, or inaccuracy of data.

Not a substitute for OneCall.

Proposed Sewer Rehab - Hwy 111







CITY OF SPARTA Burley, Love, Riverview, Wagoner & Hwy 111 Sewer Projects Bid Sheet

Bid Price to complete all street (B projects as described	urley, Love, Riverview & W	/agoner St) Sewer
\$		
Bid Price to complete Highway 11	11 project as described \$	
By submission of this bid, each bid bidder certifies, and in the case of own organization, under penalty obelief that each bidder is not on the To view the list please visit websit https://www.tn.gov/assets/entities pursuant to Tenn. Code Ann. 12-2	f a joint bid each party ther of perjury, that to the best one list created pursuant to { te below: /generalservices/cpo/attack	eto certifies as to its of its knowledge and §12-12-106. hments/List of persons
Signed:		
Company Name		
Address		
e-mail address		
Signed	_Phone	_Fax
Date	_	

For Title VI and IX compliance, it is requested that the following information be voluntarily disclosed and returned with your bid:

GENDER	Male	Female	
RACE American	Caucasian	African	
	Other (Please S	Other (Please Specify	

The City of Sparta does not discriminate based on race, color, or national origin in federal or state sponsored programs, pursuant to Title VI of the Civil Rights Act of 1964 (42 U.S.C 2000d)